

ADDENDUM NUMBER: 5
UNC CHARLOTTE
ELM, MAPLE AND PINE RESIDENCE HALLS RENOVATIONS
SCO#120994003 - Code: 41226 - Item 307
PROJECT NUMBER 3523-00
February 5, 2016

NOTICE TO CONTRACTORS

This Addendum issued prior to receipt of Bid shall and does hereby become a part of the Construction Documents for the above project.

All principal Contractors shall be responsible for seeing that their Subcontractors are properly apprised of the contents of this Addendum.

All information contained in this Addendum shall supersede and shall take precedence over any conflicting information in the original Bidding Documents dated 12/18/15 and all previous Addendum.

All Contractors shall acknowledge receipt of this Addendum in the space provided in the Proposal Form. Failure to do so may subject Bidder to disqualification.

A. CHANGES TO PRIOR ADDENDA

No changes.

B. CHANGES TO BIDDING REQUIREMENTS

No changes.

C. CHANGES TO CONDITIONS OF THE CONTRACT

No changes.

D. CHANGES TO SPECIFICATIONS

SECTION – 22 11 13 FACILITY WATER DISTRIBUTION PIPING

a. 2.02.A

Add: " 3. ISCO PP-RCT (suitable for high temperature potable water) polypropylene piping systems (<http://www.isco-pipe.com/home/>) will be an acceptable supplier of buried facility water piping.

SECTION - 23 21 13 HYDRONIC PIPING

a. 2.01.B.

Add: " 10. ISCO PP-RCT polypropylene piping systems (<http://www.isco-pipe.com/home/>) will be an acceptable supplier of buried chilled / hot water piping."

E. CHANGES TO DRAWINGS

No Changes.

End of Addendum