

January 8, 2013

McKim & Creed Project No. 05055-0005

Addendum Number 2

**University of North Carolina Charlotte
Emergency Power Upgrades to Supply Telecommunication Equipment
Code 40726 Item 320
SCO ID No. 09-08067-02A**

NOTICE TO ALL BIDDERS AND HOLDERS OF CONTRACT DOCUMENTS

The information contained herein is intended to modify and/or clarify the Contract Documents. The addendum shall and does become a part of the Contract Documents and shall be covered in the Contractor's proposal for the work.

It is the Contractor's responsibility to ascertain, prior to bid time, the addenda issued and to see that this bid includes any changes required. Prime Contractors shall see that their sub-contractors and suppliers are in receipt of information contained in all addenda.

All bidders shall acknowledge receipt of this Addendum in the space provided on the Form of Proposal.

This Addendum consists of 2 pages

SPECIFICATIONS:

Project Manual (0) ITEMS

DRAWINGS:

Item 1. Add to sheet M100 Mechanical Plan the following General Notes.

1. All equipment to be installed according to manufacturer recommendations.



5625 Executive Center Drive

Suite 200

Charlotte, NC 28212

704.945.3340

Fax 704.532.9673

www.mckimcreed.com

2. All refrigerant piping to be sized per manufacturer recommendations. Provide 1" Armaflex insulation on refrigerant suction piping. Where piping is exposed outdoors provide UV protection.
3. All refrigerant piping to be installed in walls or above ceilings. Where there are no ceilings, piping to be installed in a neat manner so as not to conflict with existing utilities and equipment.
4. All electrical work to conform to division 26 specifications and the National Electrical Code, NFPA 70.

End of Addendum Number 2