

Addendum Number 2

Project: UNCC McEniry Electrical Repairs Phase 1
SCO ID#20-22572-01A

Date: June 25, 2025

Owner: UNC Charlotte

Designer: CMTA, Inc.

NOTICE TO BIDDERS

This addendum is issued prior to receipt of bids, proposals, and its contents do hereby become a part of the pricing documents for the above referenced project.

All trade contractor bidders are responsible for assuring that their subcontractors and vendors are properly apprised of the contents of this Addendum.

All information contained in this Addendum supersedes and takes precedence over any conflicting information in the original pricing documents.

All bidders must acknowledge receipt of this Addendum in the space provided on the Bid Form for their bid package.

GENERAL INFORMATION

The bid date has been changed to **Monday, July 7, 2025 at 12pm**

CHANGES TO THE SPECIFICATIONS

1. 00 11 13 - Notice to Bidders
 - a. This form is being reissued in its entirety to update Bid Date Room location information.

CHANGES TO THE DRAWINGS

1. G000 – Cover Sheet
 - a. No changes to the drawings.
2. G002 – Appendix B
 - a. No changes to the drawings.
3. C010 – NOTES
 - a. No changes to the drawings.
4. C100 – Existing Conditions Plan
 - a. No changes to the drawings.
5. C200 – Demolition Plan
 - a. Updated Alternate numbering and associated information.

6. C300 – Site Plan
 - a. Added note for existing utility pipes depth.
 - b. Updated Alternate numbering and associated information.
7. C390 – Site Details
 - a. Added notes for minimum depth requirements.
8. E100 – Electrical Site Plan – Existing
 - a. Updated names of electrical equipment.
 - b. Added the location of the existing generator annunciator panel.
9. E101 – Electrical Site Plan – Demolition Phase
 - a. Updated names of electrical equipment.
 - b. Added the location of the existing generator annunciator panel.
 - c. Added note to remove the existing generator annunciator panel.
10. E102 – Electrical Site Plan – New Work Phase
 - a. Updated names of electrical equipment.
 - b. Updated location of enclosed circuit breaker per SCO comment.
11. E103 – Electrical Site Plan – Cleanup Phase
 - a. Updated names of electrical equipment.
 - b. Updated location of enclosed circuit breaker per SCO comment.
12. E104 – Electrical Plan – Greenhouse
 - a. Updated names of electrical equipment.
 - b. Updated location of generator annunciator panel.
 - c. Added location of ATS annunciator panel.
 - d. Updated note for generator annunciator panel to be provided.
 - e. Added note for ATS annunciator panel.
13. E600 – One-Line Power Service Diagram – Existing and Demolition
 - a. Updated names of electrical equipment.
14. E601 – One-Line Power Service Diagram – New
 - a. Updated names of electrical equipment.
 - b. Added ground size for generator.
 - c. Added ground size for enclosed circuit breaker serving Greenhouse.
 - d. Added new tag and schedule for ungrounded feeders.
 - e. Removed conduit from ATS^MTS-0101 to EPMS connection.
 - f. Updated riser diagram to show existing conduits to the Greenhouse.
 - g. Added a note for the existing conduit to the Greenhouse.
15. E602 – Greenhouse Power Riser Diagrams – Existing and New
 - a. Updated names of electrical equipment.
 - b. Updated line-weights for existing equipment and conduits.
 - c. Added notes for existing conduits to be reused.
 - d. Updated riser diagram to show location of ATS annunciator panel.
16. E700 – Electrical Details
 - a. No changes to the drawings.
17. E800 – Panelboard Schedules
 - a. Updated names of electrical equipment.

ATTACHMENTS

1. Notice to Bidders
2. Complete Drawing Set

End of Addendum 2 Narrative